



basic  
laboratory

www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

WEAVERVILLE CSD  
WES SCRIBNER  
POST OFFICE BOX 1510  
WEAVERVILLE CA 96093

Report Date: 04/20/17  
Lab Sample ID: 17C1196-01

System Name: WEAVERVILLE C.S.D.  
Source Name: 5310001-AAD-A Douglas City Element-Cafeteria interior  
Client Sample ID: 531001-03-01  
Sampled By: TIM KASPER  
Employed By: WEAVERVILLE CSD

Sample Date: 03/29/17 06:04  
Sample Received: 03/30/17 08:43  
User ID: ATT  
System Number: 5310001  
Source Code: AAD-A

Inorganic Chemical

STORET	PARAMETER	UNITS	RESULTS	MCL	DLR
01051	Lead	ug/l	ND	15	5.0

Approved By: \_\_\_\_\_

*Ricky Jensen*

Submitted By: \_\_\_\_\_ Date: \_\_\_\_\_

Basic Laboratory, Inc.  
California ELAP Cert #1677 and #2718

cc: OFFICE OF DRINKING WATER KLAMATH DISTRI



basic  
laboratory

www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

WEAVERVILLE CSD  
WES SCRIBNER  
POST OFFICE BOX 1510  
WEAVERVILLE CA 96093

Report Date: 04/20/17  
Lab Sample ID: 17C1196-02

System Name: WEAVERVILLE C.S.D.  
Source Name: 5310001-AAD-B Douglas City Element-Rm. 7, Sink  
Client Sample ID: 531001-03-02  
Sampled By: TIM KASPER  
Employed By: WEAVERVILLE CSD

Sample Date: 03/29/17 06:07  
Sample Received: 03/30/17 08:43  
User ID: ATT  
System Number: 5310001  
Source Code: AAD-B

**Inorganic Chemical**

STORET	PARAMETER	UNITS	RESULTS	MCL	DLR
01051	Lead	ug/l	ND	15	5.0

Approved By: \_\_\_\_\_

*Ricky Jensen*

Submitted By: \_\_\_\_\_ Date: \_\_\_\_\_

Basic Laboratory, Inc.  
California ELAP Cert #1677 and #2718

cc: OFFICE OF DRINKING WATER KLAMATH DISTRI



basic  
laboratory

www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

WEAVERVILLE CSD  
WES SCRIBNER  
POST OFFICE BOX 1510  
WEAVERVILLE CA 96093

Report Date: 04/20/17  
Lab Sample ID: 17C1196-03

System Name: WEAVERVILLE C.S.D.  
Source Name: 5310001-AAD-C Douglas City Element-Conference Rm. Ext.  
Client Sample ID: 531001-03-03  
Sampled By: TIM KASPER  
Employed By: WEAVERVILLE CSD

Sample Date: 03/29/17 06:09  
Sample Received: 03/30/17 08:43  
User ID: ATT  
System Number: 5310001  
Source Code: AAD-C

Inorganic Chemical

STORET	PARAMETER	UNITS	RESULTS	MCL	DLR
01051	Lead	ug/l	ND	15	5.0

Approved By: \_\_\_\_\_

*Ricky Jensen*

Submitted By: \_\_\_\_\_ Date: \_\_\_\_\_

Basic Laboratory, Inc.  
California ELAP Cert #1677 and #2718

cc: OFFICE OF DRINKING WATER KLAMATH DISTRI



www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

WEAVERVILLE CSD  
WES SCRIBNER  
POST OFFICE BOX 1510  
WEAVERVILLE CA 96093

Report Date: 04/20/17  
Lab Sample ID: 17C1196-04

System Name: WEAVERVILLE C.S.D.  
Source Name: 5310001-AAD-D Douglas City Element-Rm. 8, interior dri  
Client Sample ID: 531001-03-04  
Sampled By: TIM KASPER  
Employed By: WEAVERVILLE CSD

Sample Date: 03/29/17 06:12  
Sample Received: 03/30/17 08:43  
User ID: ATT  
System Number: 5310001  
Source Code: AAD-D

**Inorganic Chemical**

STORET	PARAMETER	UNITS	RESULTS	MCL	DLR
01051	Lead	ug/l	ND	15	5.0

Approved By: \_\_\_\_\_

Submitted By: \_\_\_\_\_ Date: \_\_\_\_\_

Basic Laboratory, Inc.  
California ELAP Cert #1677 and #2718

cc: OFFICE OF DRINKING WATER KLAMATH DISTRI



www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

WEAVERVILLE CSD  
WES SCRIBNER  
POST OFFICE BOX 1510  
WEAVERVILLE CA 96093

Report Date: 04/20/17  
Lab Sample ID: 17C1196-05

System Name: WEAVERVILLE C.S.D.  
Source Name: 5310001-AAD-E Douglas City Element-Main office, ext. d  
Client Sample ID: 531001-03-05  
Sampled By: TIM KASPER  
Employed By: WEAVERVILLE CSD

Sample Date: 03/29/17 06:14  
Sample Received: 03/30/17 08:43  
User ID: ATT  
System Number: 5310001  
Source Code: AAD-E

**Inorganic Chemical**

STORET	PARAMETER	UNITS	RESULTS	MCL	DLR
01051	Lead	ug/l	ND	15	5.0

Approved By: \_\_\_\_\_

*Ricky Jensen*

Submitted By: \_\_\_\_\_ Date: \_\_\_\_\_

Basic Laboratory, Inc.  
California ELAP Cert #1677 and #2718

cc: OFFICE OF DRINKING WATER KLAMATH DISTRI